



IF MOUNTED OUTDOORS, IT SHOULD BE PLACED SO ROOF RUN-OFF WATER DOES NOT POUR DIRECTLY ON THE UNIT AND SHOULD BE UNRESTRICTED AT LEAST 12 INCHES FROM ALL SIDES.

TITAN HEAT PUMPS

MODEL	HP	NOMINAL BTUH/KW RATING	VOLTS/PHASE	AMPS, RLA/LRA	WATER MIN/MAX FLOW RATE (GPM)	H	L	AIR OUTLET (CFM)	AMBIENT AIR TEMPERATURE *MIN/MAX	SHIPPING WEIGHT (lbs.)
HP-1	1.5	18,000/5.2	208-240/1	6/38	20/40	54"	41"	1550	50/120 °F	350
HP-2	2	24,000/7	208-240/1	8.7/57	20/40	54"	41"	1550	50/120 °F	365
HP-3	3	36,000/10.5	208-240/1	14/91	20/40	56"	41"	2175	50/120 °F	380
HP-33	3	36,000/10.5	208-240/3	10.9/74	20/40	56"	41"	2175	50/120 °F	380
HP-33-460	3	36,000/10.5	460/3	5.5/38	20/40	56"	41"	2175	50/120 °F	380
HP-4	4	48,000/14	208-240/1	18.6/94	30/60	62"	47"	2500	50/120 °F	450
HP-43	4	48,000/14	208-240/3	13.7/101	30/60	62"	47"	2500	50/120 °F	450
HP-43-460	4	48,000/14	460/3	7.1/51	30/60	62"	47"	2500	50/120 °F	450
HP-5	5	60,000/17.5	208-240/1	25/148	30/60	64"	55"	3700	50/120 °F	485
HP-53	5	60,000/17.5	208-240/3	18.6/139	30/60	64"	55"	3700	50/120 °F	485
HP-53-460	5	60,000/17.5	460/3	9/71	30/60	64"	55"	3700	50/120 °F	485

* WITH LOW AMBIENT CONTROLS UNIT WILL RUN DOWN TO 0°F

NOTE: ALL SINGLE PHASE UNITS HAVE A 13 SEER RATING. ALL THREE PHASE UNITS HAVE A 10 SEER RATING



Aqua Logic, Inc.
8268 Clairemont Mesa Blvd. Suite 302
San Diego, CA 92111

TITLE: HP-1 THRU HP-53
HEAT PUMPS

LAST UPDATE: 1-19-07

DATE: 12-15-04

FILE:HP-1 thru 53 spec

BY: CE